


Note:-  
 PUDLO PS Cure 90 is spray applied to the surface of newly placed concrete to prevent premature drying out of the concrete surface, reducing surface shrinkage, cracking and dusting.



1 No. Surestop BWB to be wrapped around pipe and secured with tie wire (minimum 75mm from surface of wall).

2 No. 2mm thick coats of PUDLO Render Seal 2C.

Slab cast in PUDLO CWP Modified Concrete.

Post drilled pens. to be spaced min. 100mm edge-to-edge. Waterbars secured to pipes should be staggered to allow adequate spacing.

Surestop BWB to be adhered using Surestop Adhesive, with a 10mm continuous bead of Surestop SM applied above.

PS Hi-Flow Grout MUST go entire depth of post drilled hole.

PS Hi-Flow Grout to seal cavity.

Note :-  
 Before any drilling works/core areas are removed from PUDLO CWP Modified Concrete please contact your site support team representative.  
 Any works being started prior to consulting PUDLO may result in the works being excluded from the warranty.



Revision History

DATE	DESCRIPTION	Rev	Drn	Chk	Apvl
20/05/24	First issue.		JB	DN	--

PUDLO Products Limited  
 Unit 1, Alington Road,  
 St Neots, PE19 6YH  
 Tel: +44 (0)1480 756888 Email: sales@pudlo.com  
 www.pudlo.com

DRAWING TITLE	PROJECT		
SLAB PIPE PENETRATION (POST DRILLED) DETAIL	--		
STATUS	SCALE	1:10 on A4	
--			
DRAWING NUMBER	REVISION	SHEET No.	
PPL-TJD-P2.5-SS-004	-	1 of 1	
CLIENT	--		
COPYRIGHT: Not to be reproduced without written permission	A4	PUDLO Products Limited STD April 2024	

Note:-

This PUDLO detail is to assist with the installation of its products. The detail shows how PUDLO CWP Modified Concrete and how PUDLO ancillaries are to be installed. For site specific details and confirmation on extent of where PUDLO CWP Modified Concrete is used i.e. Overlay drawings, must be confirmed by structural engineers/contractor. Individual/Company responsibility for design of the structure must ensure that details shown on PUDLO drawings match the latest construction issue drawings.

The information shown on this detail is given without obligation, or warranty PRIOR to consultation or communication with PUDLO Products Limited.