



Pour Three - Slab to be cast in PUDLO CWP Modified Concrete.

Wall heads and kickers to be retarded with PUDLO System Liquid Retarder and jet washed off prior to next pour to leave clean, exposed aggregate.

Pour Two - Lift pit wall to be cast in PUDLO CWP Modified Concrete.

Rebate formed in top of kicker using Surestop Void Former. Surestop BWB pushed into rebate and continuously adhered using Surestop Adhesive (minimum 75mm cover).

PUDLO Self Seal to lap PUDLO BW Membrane, come across pile cap and terminate at kicker joint to form a continual Type A system. PUDLO Self Seal Primer to be applied prior to PUDLO Self Seal.

Pour One - Top of slab/pile cap to be cast monolithically in PUDLO CWP Modified Concrete.

Pour One - Bottom of slab/pile cap to be cast in reinforced concrete.

PS Termination Strap to membrane transition.

PUDLO BW Membrane.

For pile head please refer to PUDLO drawing; 'PPL-TJD-BW-DS-021'.



Revision History

DATE	DESCRIPTION	Rev	Drm	Chk	Apvl
28/05/24	First Issue.			JB	DN

PUDLO Products Limited
 Unit 1, Alington Road,
 St Neots, PE19 6YH
 Tel: +44 (0)1480 756888 Email: sales@pudlo.com
 www.pudlo.com

DRAWING TITLE	PROJECT
LIFT PIT DETAIL 3	--
STATUS	SCALE
--	1:25 on A3
DRAWING NUMBER	REVISION
PPL-TJD-P2.5-DS-019	-
CLIENT	SHEET No.
--	1 of 1

Note:- This PUDLO detail is to assist with the installation of its products. The detail shows how PUDLO CWP Modified Concrete and how PUDLO ancillaries are to be installed. For site specific details and confirmation on extent of where PUDLO CWP Modified Concrete is used i.e. Overlay drawings, must be confirmed by structural engineers/contractor. Individual/Company responsibility for design of the structure must ensure that details shown on PUDLO drawings match the latest construction issue drawings. The information shown on this detail is given without obligation, or warranty PRIOR to consultation or communication with PUDLO Products Limited.